

HOW TO CHANGE YOUR CFU MEDIA

Models: CFU5, CFU8, CFU10, CFU15, CFU18, CFU23, CFU30/30D

Total time required approx. 30 minutes

1. Turn off water supply via Inlet valve on 3 valves by pass.

Relieve pressure by opening mains cold water tap after Scaleout unit.



2. Remove both red clips.

3. Remove inlet and outlet connector..
Be aware there will be water spillage from these connections.



4. With unit free of inlet and outlet connections, it should look as picture right?



5. Insert white gripper (supplied) and refix red clip.



6. Undo head applying pressure anticlockwise to remove head from bottle.
Extra pressure may be required i.e. rubber or wooden mallet.

Please **DO NOT USE** a metal hammer.



7. Remove head complete with internal tube. Be aware of slight water spillage here.



8. Empty spent media. This can be disposed of safely with your normal household rubbish.

Rinse out bottle with cold water. Remove central grey tube from the head and place back in the bottle. Add Milton solution (not supplied) and leave to sterilise. Add red cap (supplied) over the top of the grey tube. This is to stop new media entering and causing damage downstream on the unit.

Gently pour new media into the bottle using a funnel if possible (not supplied)



9. Clean top of vessel where head 'o' ring joins for seal and apply a small amount of Vaseline to 'o' ring and head seal area to help the heads main 'o' ring to seal.

Screw head on to bottle clockwise after carefully sliding the yellow 'basket' over the grey tube. When you are engaging the first threads of the head into the bottle, you may feel a slight resistance. This is normal as it is the grey tube engaging with the heads internal 'o' ring to seal.



11. Reconnect inlet and outlet connection.

IMPORTANT: Insert both red clips.



12. Disconnect outlet hose from appliance and run water from outlet hose to drain to rinse resin as per original instructions, namely;

CFU5 flush for 15 litres minimum
CFU10 flush for 30 litres minimum
CFU15 flush for 45 litres minimum
CFU18 flush for 60 litres minimum
CFU23 flush for 70 litres minimum
CFU30 flush for 100 litres minimum
CFU30D flush for 100 litres minimum per vessel.

Reconnect outlet hose to appliance, turn on water supply and check for leaks.



Monarch Water Ltd, Halesworth Road, Bramfield, Suffolk, IP19 9HP.
Tel 01986 784759. Fax 01986 784769.

www.monarchwater.co.uk www.scaleout.co.uk sales@monarchwater.co.uk